FIRE SAFETY CERTIFICATE

No. FB/4458

Dated: 14/02/2014

Certified that the Eureka International School (name of the building or premises) at Dhayari, Tal- Haveli, Dist. Pune, 411041 (address) comprised of G wasement (s) and +5 (upper floors) owned/occupied by Eureka International School (name of the institution) have complied with the fire prevention and fire safety requirements in accordance with rule of State/ UT Fire Service Rules, and verified by the officers concerned of Fire Service 10-12-2023 (date of inspection) in the presence of Principal Eureka International School (name and addresses of the Manager/ Secretary or his representative) and that the building/premises is fit for occupancy upto classes Xth With effect from 20-12-2023 for a period of 03 year in accordance with rule and subject to compliance of specific7

conditions as appended:-

- 1. All the Electrical wiring in the building in concealed condition.
- 2. Every floor must bear min. 2 fire extinguishers (Co2 and ABC type)
- 3. Terrace of the building should not be use for commercial purpose.
- 4. School should arrange fire mock drill for students every year.

Issued on 20-12-2023.(date of issue) at Pune. (place) by

*Strike out whichever is not applicable.

Signature with Seal:!

Name

Designation

रनेशन हच्छी ऑफिसर अगिनशमन दल, पुणे म.न.पा.

To, **Principal** Eureka International School (Name & Address of the Institution)

ENDORSEMENT

The No Objection Certificate issued by Fire Service stand cancelled an annulled due to Violation of any of the above conditions.

(Name and designation of the authorized signatory)

*The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.